



BLUESKIN PRESEAL 320
OR **BLUESKIN PRESEAL 435** (SEE NOTE #2)

HENRY 925 BES SEALANT
(EXTEND 3/4" (20MM) EACH SIDE)

BLUESKIN PRESEAL TAPE 120V

BLUESKIN PRESEAL TAPE 120V

MIRASTOP BW OR MIRASTOP NBW
(3" (75MM) MINIMUM CONCRETE
COVERAGE ON ALL SIDES)

PVC OR METAL PIPE

6" (150MM)
MINIMUM
BETWEEN
PIPES

SOIL RETENTION SYSTEM
(DO NOT INSTALL **BLUESKIN PRESEAL 320**
DIRECTLY ONTO SHEET PILING - PREPARE
SUBSTRATE WITH A SMOOTH SURFACE SUCH
AS PLYWOOD OR DRAINBOARD)

HENRY DRAINBOARD (SEE NOTE #3)

NOTES:

1. DETAIL SHOWS HENRY PRE-APPLIED WATERPROOFING SYSTEM FOR APPLICATIONS USING HENRY **BLUESKIN PRESEAL 320** OR **BLUESKIN PRESEAL 435**. SUBSTRATE SHOWN IS FOR REFERENCE ONLY.
2. HENRY **BLUESKIN PRESEAL 435** CAN BE INSTALLED DIRECTLY ONTO SHEET PILING. **BLUESKIN PRESEAL 320** REQUIRES A SMOOTH SURFACE SUCH AS PLYWOOD OR DRAINBOARD.
3. HENRY RECOMMENDS THE USE OF A DRAINBOARD IN NON-HYDROSTATIC CONDITIONS, OR AS A SUBSTRATE PREPARATION.
4. REFER TO PRODUCT SPECIFIC TECHNICAL DATA SHEET AND GUIDE SPECIFICATION FOR INSTALLATION PROCEDURES.



MANUFACTURER GUIDE DETAILS ARE FOR REFERENCE ONLY. HENRY DOES NOT ASSUME RESPONSIBILITY FOR ERRORS OR DEVIATIONS IN DESIGN OR ENGINEERING. PROJECT SPECIFIC VERIFICATION IS RECOMMENDED PRIOR TO INSTALLATION.

HENRY PRE-APPLIED WATERPROOFING SYSTEM

WALL PENETRATION

BLUESKIN PRESEAL 320 OR BLUESKIN PRESEAL 435
WALL PENETRATION - MULTIPLE PIPES

SCALE: N.T.S. | 11-06-2023

BSPS-6A.2