



PRETREAT EXISTING ROOF SEAM PRIOR TO **PRO-GRADE® 988** COATING INSTALLATION USING ONE OF THE METHODS BELOW: (STAIN BLOCKING PRIMER REQUIRED FOR EXISTING MB/BUR ROOFS -SEE NOTE #2)

- SEALANT (125 WET MILS); EXTEND SEALANT 2" MINIMUM AT EACH SIDE OF SEAM:
 - **PRO-GRADE® 920**
 - **PRO-GRADE® 923**
 - **PRO-GRADE® 957**
- REINFORCED COATING (32 WET MILS); EXTEND COATING 4" MINIMUM AT EACH SIDE OF SEAM AND REINFORCE WITH 6" WIDE **195 POLYESTER FABRIC**

CONTACT HENRY® FOR ROOFING UNDERLAYMENT REPAIR OPTIONS WHERE REQUIRED

EXISTING ROOF SEAM

PRO-GRADE® 988
(OPTIONAL RUST INHIBITIVE PRIMER FOR EXISTING METAL ROOFS -SEE NOTE #2)

NOTES:

1. DETAIL SHOWS **PRO-GRADE® 988** INSTALLED OVER AN EXISTING PREVIOUSLY COATED OR NON-COATED METAL ROOFING ASSEMBLY.
2. OPTIONAL RUST INHIBITIVE PRIMER NOT SHOWN FOR CLARITY.
3. REMOVE EXISTING SEAM COATING, MASTICS AND SEALANTS AND COMPLETE ALL DETAILING PRIOR TO INSTALLATION OF ROOF COATING.
4. HORIZONTAL LAPS, UN-CRIMPED VERTICAL SEAMS AND RIDGE CAP SEAMS MAY REQUIRE STITCH-FASTENING PRIOR TO COATING INSTALLATION TO ENSURE A CONTINUOUS SUBSTRATE AND GAP ELIMINATION.
5. DECK AND EXISTING ROOFING ASSEMBLY SHOWN ARE FOR REFERENCE ONLY.
6. REFER TO **PRO-GRADE® 988** GUIDE SPECIFICATION, INSTALLATION MANUAL AND/OR APPLICATION GUIDE FOR RECOMMENDED INSTALLATION PROCEDURES.
7. REFER TO **PRO-GRADE® 988** WARRANTY CHART FOR SUBSTRATE SPECIFIC FIELD COATING MINIMUM REQUIREMENTS.

Henry®

999 N. Sepulveda Blvd., Suite 800
El Segundo, CA 90245
800-486-1278 • www.henry.com

MANUFACTURER GUIDE DETAILS ARE FOR REFERENCE ONLY. HENRY® DOES NOT ASSUME RESPONSIBILITY FOR ERRORS OR DEVIATIONS IN DESIGN OR ENGINEERING. PROJECT SPECIFIC VERIFICATION IS RECOMMENDED PRIOR TO INSTALLATION.

PRO-GRADE® 988 SILICONE ROOF COATING

SEAM PRE-TREATMENT

PRE-TREATMENT OF EXISTING INTACT AND SECURE SEAMS ON A METAL ROOF

SCALE: N.T.S.

06-20-2017

PG988-11B