



NOTES:

1. DETAIL SHOWS **PRO-GRADE® 988** INSTALLED OVER AN EXISTING PREVIOUSLY COATED OR NON-COATED METAL ROOFING ASSEMBLY.
2. OPTIONAL RUST INHIBITIVE PRIMER NOT SHOWN FOR CLARITY.
3. REMOVE EXISTING SEAM COATING, MASTICS AND SEALANTS AND COMPLETE ALL DETAILING PRIOR TO INSTALLATION OF ROOF COATING.
4. HORIZONTAL LAPS, UN-CRIMPED VERTICAL SEAMS AND RIDGE CAP SEAMS MAY REQUIRE STITCH-FASTENING PRIOR TO COATING INSTALLATION TO ENSURE A CONTINUOUS SUBSTRATE AND GAP ELIMINATION.
5. DECK AND EXISTING ROOFING ASSEMBLY SHOWN ARE FOR REFERENCE ONLY.
6. REFER TO **PRO-GRADE® 988** GUIDE SPECIFICATION, INSTALLATION MANUAL AND/OR APPLICATION GUIDE FOR RECOMMENDED INSTALLATION PROCEDURES.
7. REFER TO **PRO-GRADE® 988** WARRANTY CHART FOR SUBSTRATE SPECIFIC FIELD COATING MINIMUM REQUIREMENTS.

Henry®

999 N. Sepulveda Blvd., Suite 800
El Segundo, CA 90245
800-486-1278 • www.henry.com

MANUFACTURER GUIDE DETAILS ARE FOR REFERENCE ONLY. HENRY® DOES NOT ASSUME RESPONSIBILITY FOR ERRORS OR DEVIATIONS IN DESIGN OR ENGINEERING. PROJECT SPECIFIC VERIFICATION IS RECOMMENDED PRIOR TO INSTALLATION.

PRO-GRADE® 988 SILICONE ROOF COATING

PIPE PENETRATION
PLUMBING VENT OR PIPE PENETRATION
ON A METAL ROOF - METHOD A

SCALE: N.T.S.

06-20-2017

PG988-7B