



Notes:

1. The flashing membrane is looped down into the joint to a depth of 1.5 times the width of the joint.
2. The minimum requirement for the termination bar is that it be 1" wide, made of aluminum or galvanized metal, and be pre-drilled on a maximum spacing of 12".
3. Where excessive movement or vibration is expected, the designer should consider using a termination bar, mechanically fastened through the flashing sheet 12" o.c. on both sides of the joint.
4. Protection Layer not shown for clarity.

Henry
COMPANY®
www.henry.com

790-11 WATERPROOFING

SCALE: N.T.S.

JOINTS 1/2" TO 2"

06-03-09

**EXPANSION JOINT
DETAIL**

WP-H111